



This document does not permit the holder to violate any BAAQMD regulation or any other law.

PERMIT EXPIRATION DATE
November 01, 2019



Owner Mailing Contact:

University of CA-Richmond Field St
1301 S 46th St Bldg 478
Richmond , CA 94804-4604
Attn: Doug Wood



Facility ID: 109842

University of CA-Richmond Field Station
1301 S 46th St
Richmond , CA 94804-4600

10-01-18P01:57 RCVD

Owning Entity:

University of California



DEVICES

This document serves as your Permit to Operate the following:

S1 Permitted

Gasoline Dispensing Operation

Tank Information:

1500 Gallon Tank w/ Gasoline - unleaded
Phase I Vapor Recovery Type: Non-EVR Two Point
Phase II Vapor Recovery Type: Balance (Non-EVR)

Nozzle Information:

1 Gasoline - Single Product

The operating parameters described above are based on information supplied by the permit holder and may differ from the limits set forth in the attached conditions of this Permit To Operate. The limits of operation in the permit conditions are not to be exceeded. Exceeding these limits is considered a violation of BAAQMD and is subject to enforcement action.



PERMIT CONDITIONS

The devices described in this document are subject to the following permit conditions:

S1 Subject to Condition #: 14098, 16516

Condition #: 14098 S1

Pursuant to BAAQMD Toxic Section Policy, this facility's annual gasoline throughput shall not exceed 940,000 gallons in any consecutive 12 month period.

Condition #: 16516 S1



This document does not permit the holder to violate any BAAQMD regulation or any other law.

**PERMIT EXPIRATION DATE
November 01, 2019**

The owner/operator of the facility shall conduct and pass a Static Pressure Performance Test (LeakTest) CARB TP 206.3 at least once in each twelve consecutive month period after the date of successful completion of the startup Static Pressure Performance Test.

The owner/operator shall:

1. Notify Source Test by email (gdfnotice@baaqmd.gov) or Fax (510-758-3087), at least 48 hours prior to any required testing.
2. Submit test results in a District-approved format within thirty (30) days of testing.
 - For start-up tests results, cover sheet shall include the facility number (Facility ID) and application number of the Authority to Construct permit.
 - For annual test results, cover sheet shall include the facility number (Facility ID) and identified as 'Annual' in lieu of the application number.
 - Test results shall be emailed (gdfresults@baaqmd.gov) or mailed to the District's main office.

END OF CONDITIONS



IMPLIED CONDITIONS

Unless your specific permit conditions state otherwise, the throughputs, fuel and material consumptions, capacities and hours of operation described in your permit application will be considered maximum allowable limits.

A new permit will be required before any increase in parameters, such as throughputs, fuel and material consumption, capacities, and hours of operation, or change in materials, equipment or permit conditions may be made.



RIGHT OF ACCESS

In accordance with Regulation 1-440, BAAQMD shall be granted the right of access to any premises on which an air pollution source is located for the purposes of:

- a) The inspection of the source,
- b) The sampling of materials used at the source,
- c) The conduct of an emission source test, and
- d) The inspection of any records required by BAAQMD rule or permit condition



REGULATORY COMPLIANCE

This Permit To Operate does not authorize violations of the rules and regulations of BAAQMD (may be viewed at www.baaqmd.gov), California or Federal law. Compliance with conditions in this permit does not mean that the permit holder is currently in compliance with BAAQMD Rules and Regulations. It is the responsibility of the permit holder to have knowledge of and be in compliance with all BAAQMD rules and regulations.

END OF DOCUMENT