

# Edmond's Café ( International House )

UCB Follow-Up Inspection - Food

Managers

Cedric Martin

Inspection Date

Mar 30, 2022

Inspection Contributors

Muzna Rauf

Reference ID

## Notes

---

Follow-up inspection was conducted to check for compliance of violation #21a as observed on inspection report dated 03/16/2022.

A re-inspection was conducted on 03/18/2022, and the hot water temperature at the 3-compartment warewash sink was measured at 112 degrees F. As per person in charge, a hot water booster has been purchased and is waiting to be installed. Operator instructed to have all dishes from the café be washed in the dining hall kitchen until the booster is installed. The café was closed during spring break from 03/21/2022 to 03/25/2022.

— Muzna Rauf

## Observations and Corrective Actions \*

---

Observations and Corrective Actions

Public Comments: As of 03/30/2022, hot water continues to be measured at 112 degrees F at the 3-compartment warewash sink. Hot water booster has not been installed. Operator instructed to have staff continue washing dishes from the café in the dining hall kitchen. Re-inspection to check for compliance to be scheduled once operator notifies EHS of hot water booster installation being complete.

Inspector: Muzna Rauf

Status: Not Compliant

Resolution:

### Resolved

Resolved on Apr 11, 2022

Updated by Muzna Rauf on Apr 15, 2022

On re-inspection, hot water at the 3-compartment sink was measured at greater than equal to 120 degrees F.