

# The Golden Bear Café ( Cesar Chavez Student Center )

## UCB Follow-Up Inspection - Food

### Managers

Stefan Vogelsang, Stephanie Stephens,  
Sunil Chacko, Michael Oldham, Jason Maddy

### Inspection Date

Mar 27, 2023

### Inspection Contributors

Muzna Rauf

### Reference ID

## Notes

A follow-up inspection was conducted to check for compliance of violation #21(a) observed on inspection report dated 03/08/2023.

Critical violation #21(a) has been abated. Any pending violations will be checked at next routine inspection.

— Muzna Rauf

## Observations and Corrective Actions \*

### Observations and Corrective Actions

Public Comments: Violation #21a for no hot water at the 3-compartment warewash sink and the mechanical dish machine has been corrected with reasonable compliance. Hot water temperature measured at 120 degrees F and greater at the 3-compartment warewash sink, and 125.3 degrees F during the wash cycle and 149.5 degrees F during the rinse cycle of the mechanical dish machine at the time of the re-inspection.

Inspector: Muzna Rauf

Status: Compliant